

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Mr. Than Singh Lodhi

(Name of Officers with designation) from Nagar Parishad Udaipur PHED

inspected the GURUKUL CONVENT HR. SEC. SCHOOL KHIRIYA Udaipur

(Name & Address of the school) on 11/03/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 33202513 dated 08/03/2025

of Micotech Testing And Research Laboratory (LLP) (PHED Lab) certified that the

Gurukul Convent School, Udaipur (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 03 year

Signature with Seal: Er. Thansingh Lodhi

Name : (Civil Engineer)

Designation :

Name & Address of the Office / Departmen

To GURUKUL CONVENT HR. SEC. SCHOOL

Khiriya Udaipur

(Name & Address of the Institution)

Note: The certificate is to be issued by
authorized officer / PHED Lab / local bodies



MICOTECH TESTING AND RESEARCH LABORATORY LLP

An ISO 9001:2015 Certified Testing Laboratory
(Centre for Inspection, Testing & Certification of Materials)
Near Double Lock Godown, Agesod Road, Bina, Distt.-Sagar (M.P.) 470113
Contact: 9302872982, 9630225086 Email: mtrbina@gmail.com



TEST REPORT

Issued to,	Packing, When Received: Sealed Packing
The Principal.	Quantity Received: 02 Liters
GURUKUL Convent School,	Environmental Condition: Room Temperature
Udaipura, Dist. - Raisen (M P)	Location of Test: Laboratory
Certificate No.: 33202513	Date of Receipt: 03.03.2025
Description of Sample: Drinking Water	Date of Report: 08.03.2025
Source: Bore Well	Date of Start of Test: 03.03.2025
	Date of Completion of Test: 08.03.2025
	Your Reference No.: Dated: 03.03.2025

S. No	Organoleptic Physical and General Characteristics	Test Value	Requirement as per IS:10500:2012		
			Requirement (Acceptable Limit) Max.	Max. Permissible Limit in the Absence of Alternate Source	Method of Test Ref.
1	Colour, Hazen Unit	<5	5	15	IS: 3025 - 2005
2	Odour	Agreeable	Agreeable	Agreeable	IS: 3025 - 2005
3	Taste	Agreeable	Agreeable	Agreeable	IS: 3025 - 2005
4	Turbidity, NTU	0.00	1.0	5.0	IS: 3025 - 2005
5	pH Value	7.14	6.5 - 8.5	No Relaxation	IS: 3025 - 2005
6	Total Dissolve Solids as TDS, mg/l	156	500	2000	IS: 3025 - 2005
7	Total Hardness as CaCO ₃ , mg/l	72	200	600	IS: 3025 - 2005
8	Iron as Fe, mg/l	0.12	0.3	No Relaxation	IS: 3025 - 2005
9	Chloride as Cl, mg/l	32	250	1000	IS: 3025 - 2005
10	Fluoride as F, mg/l	0.24	1.0	1.5	IS: 3025 - 2005
Bacteriological Test					
1	Total Coli form, (MPN)/ 100 ml	Absent	Shall not be detectable in any 100-ml. sample		IS: 1622 - 2005
2	E. Coli	Absent	Shall not be detectable in any 100-ml. sample		IS: 1622 - 2005

Remark: Water sample can be used for drinking purpose.

---End of Report---

Authorised Signature